

Q 3.54

67/14  
c







MAINTENANCE:

	Number of Jobs Done	Ave. Total Number Employees	Est. Value of Materials Used
On Buildings	438	17	\$472.81
On Utilities	1	1 man hour	\$ .03

OPERATION OF UTILITIES:

Average Number of Employees: Water Supply 13 Sewage Disposal 13 Electrical none  
 Est. Value Materials Used: Water Supply 150.00 Sewage Disposal 235.00 Electrical none  
 Gallons Water Used This Month 35,000,000 Per Capita Water Consumption 130 gals.

REFRIGERATION:

Number of Service Calls 96 Number Repair Jobs 31 Ave. Total Number Employees 13  
 Number of Units Inspected and Serviced This Month 42  
 Units Not Operating: (give number and size) McCray-US65-Universal Cooler #206295-2  
Coldspot Model 106214150

Explain why units not operating, how long idle, etc.

**McCray - missing parts, idle approximately four months.**

**Coldspot - compressor out of order, idle approximately three weeks.**

COMMENTS: (Discuss here any unusual or significant developments this month in construction, land development, maintenance, operation of utilities and refrigeration; problems, or difficulties encountered in getting materials, labor or equipment; etc. Use additional sheet if necessary.)







MAINTENANCE:

	Number of Jobs Done	Ave. Total Number Employees	Est. Value of Materials Used
On Buildings	468	16	\$540.50
On Utilities	9	6	\$ 90.98

OPERATION OF UTILITIES:

Average Number of Employees: Water Supply 14 Sewage Disposal 12 Electrical none

Est. Value Materials Used: Water Supply \$150.00 Sewage Disposal \$235.00 Electrical none

Gallons Water Used This Month 33,000,000 Per Capita Water Consumption 130 gals.

REFRIGERATION:

Number of Service Calls 101 Number Repair Jobs 40 Ave. Total Number Employees 13

Number of Units Inspected and Serviced This Month 42  
 McCray-US 65, Universal Cooler #206295-2

Units Not Operating: (give number and size) (3) Coldspot-Unit #1976338 Compressor  
 Sunbeam SA623 Serial # #106-214150  
 1977933

Explain why units not operating, how long idle, etc.

McCray - missing parts. Idle 5 months.

Coldspot - Compressor #106-214150, out of order. Idle 7 weeks.

Sunbeam - Idle approximately 2 weeks.

COMMENTS: (Discuss here any unusual or significant developments this month in construction, land development, maintenance, operation of utilities and refrigeration; problems, or difficulties encountered in getting materials, labor or equipment; etc. Use additional sheet if necessary.)







# MAINTENANCE:

	Number of Jobs Done	Ave. Total Number Employees	Est. Value of Materials Used
On Buildings	662	14	\$376.56
On Utilities	6	22 Man days	\$ 41.83

## OPERATION OF UTILITIES:

Average Number of Employees: Water Supply 13 Sewage Disposal 12 Electrical none  
 Est. Value Materials Used: Water Supply 120.00 Sewage Disposal 210.00 Electrical none  
 Gallons Water Used This Month 24,000,000 Per Capita Water Consumption 100 gals.

## REFRIGERATION:

Number of Service Calls 85 Number Repair Jobs 28 Ave. Total Number Employees 10  
 Number of Units Inspected and Serviced This Month 42  
 Units Not Operating: (give number and size) 3 (McCray US65 Universal Cooler 206295-2  
Coldspot Unit #1976338, Compressor 106-  
(Sunbeam SA623, Serial #1977933 21450

Explain why units not operating, how long idle, etc.

McCray - Missing parts, idle 6 months.

Coldspot - Compressor out of order, idle approximately 11 weeks.

Sunbeam, idle approximately 6 weeks.

COMMENTS: (Discuss here any unusual or significant developments this month in construction, land development, maintenance, operation of utilities and refrigeration; problems, or difficulties encountered in getting materials, labor or equipment; etc. Use additional sheet if necessary.)

Building construction has gone forward at a more rapid pace than in any like period during the year. morale has been higher and weather has been very good for this type of work. Crews have been cut below an efficient workable minimum in some cases, but we now anticipate no serious difficulty in either building the crews to full strength or reorganizing to fit changing or available man power.







MAINTENANCE:

	Number of Jobs Done	Ave. Total Number Employees	Est. Value of Materials Used
On Buildings	685	13	\$483.65
On Utilities	3	4 Man Days	15.93

OPERATION OF UTILITIES:

Average Number of Employees: Water Supply 13 Sewage Disposal 12 Electrical \_\_\_\_\_  
 Est. Value Materials Used: Water Supply 150.00 Sewage Disposal 150.00 Electrical \_\_\_\_\_  
 Gallons Water Used This Month 20,000,000 Per Capita Water Consumption 85 gals.

REFRIGERATION:

Number of Service Calls 57 Number Repair Jobs 26 Ave. Total Number Employees 10

Number of Units Inspected and Serviced This Month 42

Units Not Operating: (give number and size) 4 (McCray-US65 Universal Cooler 206295-2  
 Coldspot-Unit 1976338

Sunbeam-SA 623, Serial 1977933  
 Sunbeam-SA 623, Serial 1976368

Explain why units not operating, how long idle, etc.

**McCray - Missing parts. Idle 7 months.**

**Coldspot - Compressor out of order. Idle approximately 15 weeks.**

**Sunbeam - Serial 1977933. Idle 10 weeks.**

**Sunbeam - Serial 1976338, compressor out of order. Idle one week.**

COMMENTS: (Discuss here any unusual or significant developments this month in construction, land development, maintenance, operation of utilities and refrigeration; problems, or difficulties encountered in getting materials, labor or equipment; etc. Use additional sheet if necessary.)







MAINTENANCE:

	Number of Jobs Done	Ave. Total Number Employees	Est. Value of Materials Used
On Buildings	669	14	\$771.26
On Utilities	12	28 Man Days	15.60

OPERATION OF UTILITIES:

Average Number of Employees: Water Supply 13 Sewage Disposal 12 Electrical \_\_\_\_\_

Est. Value Materials Used: Water Supply \$150.00 Sewage Disposal \$150.00 Electrical \_\_\_\_\_

Gallons Water Used This Month 20,000,000 Per Capita Water Consumption 85 gal.

REFRIGERATION:

Number of Service Calls 57 Number Repair Jobs 25 Ave. Total Number Employees 10

Number of Units Inspected and Serviced This Month 42

Units Not Operating: (give number and size) 4 (McCray-US65 Universal Cooler 206295-2)  
1 (Coldspot-Unit 1976338)

Explain why units not operating, how long idle, etc.  
(Sunbeam SA623 Serial 1977933)  
(Sunbeam SA623 Serial 1976368)

**McCray - Missing parts. Idle 8 months.**

**Coldspot - Compressor out of order. Idle 19 weeks.**

**Sunbeam - Serial 1977933. Idle approximately 14 weeks.**

**Sunbeam - Serial 1976338. Compressor out of order. Idle 5 weeks.**

COMMENTS: (Discuss here any unusual or significant developments this month in construction, land development, maintenance, operation of utilities and refrigeration; problems, or difficulties encountered in getting materials, labor or equipment; etc. Use additional sheet if necessary.)

Excellent progress was made on the Auditorium due to good building weather and a high degree of morale among the workmen.







MAINTENANCE:

	Number of Jobs Done	Ave. Total Number Employees	Est. Value of Materials Used
On Buildings	549	14	355.62
On Utilities	9	9 Man Days	1.39

OPERATION OF UTILITIES:

Average Number of Employees: Water Supply 13 Sewage Disposal 12 Electrical       

Est. Value Materials Used: Water Supply 250.00 Sewage Disposal 150.00 Electrical       

Gallons Water Used This Month 20,150,000 Per Capita Water Consumption 85 gal.

REFRIGERATION:

Number of Service Calls 55 Number Repair Jobs 27 Ave. Total Number Employees 13

Number of Units Inspected and Serviced This Month 42

Units Not Operating: (give number and size) 4 (McCray-US65 Universal Cooler 206295-2  
(Coldspot-Unit 1976338  
(Sunbeam SA623 Serial 1977933  
(Sunbeam SA623 Serial 1976368

Explain why units not operating, how long idle, etc.

McCray - Missing parts. Idle 9 months.

Coldspot - Compressor out of order. Idle 23 weeks.

Sunbeam - Serial 1977933. Idle approximately 18 weeks.

Sunbeam - Serial 1976338. Compressor out of order. Idle 9 weeks.

COMMENTS: (Discuss here any unusual or significant developments this month in construction, land development, maintenance, operation of utilities and refrigeration; problems, or difficulties encountered in getting materials, labor or equipment; etc. Use additional sheet if necessary.)

Progress dropped materially during the past month due to weather conditions. Also, the use of all labor on other work (getting in fire wood) approximately 25% of the work period. Work morale continues high and progress will continue favorable with November, given the same number of man days of workable weather.







MAINTENANCE:

	Number of Jobs Done	Ave. Total Number Employees	Est. Value of Materials Used
On Buildings	501	16	965.22
On Utilities	11	62 Hours	33.95

OPERATION OF UTILITIES:

Average Number of Employees: Water Supply 13 Sewage Disposal 12 Electrical     

Est. Value Materials Used: Water Supply 250.00 Sewage Disposal 140.00 Electrical     

Gallons Water Used This Month 24,000,000 Per Capita Water Consumption 100 gal.

REFRIGERATION:

Number of Service Calls 45 Number Repair Jobs 24 Ave. Total Number Employees 13

Number of Units Inspected and Serviced This Month 42

Units Not Operating: (give number and size) (McCray-US65 Universal Cooler 206295-2  
(Coldspot-Unit 1976338

(Sunbeam SA 623 Serial 1977933  
(Sunbeam SA 623 Serial 1976368

Explain why units not operating, how long idle, etc.

**McCray - Missing parts. Idle 10 months.**

**Coldspot - Compressor out of order. Idle 6 months 3 weeks.**

**Sunbeam - Serial 1977933. Idle 5½ months.**

**Sunbeam - Serial 1976368. Compressor out of order. Idle 13 weeks.**

COMMENTS: (Discuss here any unusual or significant developments this month in construction, land development, maintenance, operation of utilities and refrigeration; problems, or difficulties encountered in getting materials, labor or equipment; etc. Use additional sheet if necessary.)







MAINTENANCE:

	Number of Jobs Done	Ave. Total Number Employees	Est. Value of Materials Used
On Buildings	593	16	642.04
On Utilities	6	10 $\frac{1}{2}$ Man Days	8.14

OPERATION OF UTILITIES:

Average Number of Employees: Water Supply 13 Sewage Disposal 12 Electrical \_\_\_\_\_

Est. Value Materials Used: Water Supply 250.00 Sewage Disposal 140.00 Electrical \_\_\_\_\_

Gallons Water Used This Month 22,000,000 Per Capita Water Consumption 110 gal.

REFRIGERATION:

Number of Service Calls 48 Number Repair Jobs 19 Ave. Total Number Employees 13

Number of Units Inspected and Serviced This Month 42

Units Not Operating: (give number and size) 4 (McCray - US65 Universal Cooler 206295-2  
(Coldspot - Unit 1976338  
(Sunbeam SA623 Serial 1977933  
(Sunbeam SA623 Serial 1976368

Explain why units not operating, how long idle, etc.

McCray - Missing parts. Idle 11 months.

Coldspot - Compressor out of order. Idle 7 months 3 weeks.

Sunbeam - Serial 1977933. Idle 6 $\frac{1}{2}$  months.

Sunbeam - Serial 1976368. Compressor out of order. Idle 4 months 1 week.

COMMENTS: (Discuss here any unusual or significant developments this month in construction, land development, maintenance, operation of utilities and refrigeration; problems, or difficulties encountered in getting materials, labor or equipment; etc. Use additional sheet if necessary.)







MAINTENANCE:

	Number of Jobs Done	Ave. Total Number Employees	Est. Value of Materials Used
On Buildings	660	14	716.70
On Utilities	3	4	2.30

OPERATION OF UTILITIES:

Average Number of Employees: Water Supply 13 Sewage Disposal 12 Electrical \_\_\_\_\_

Est. Value Materials Used: Water Supply \$150.06 Sewage Disposal \$100. Electrical \_\_\_\_\_

Gallons Water Used This Month 23,470,000 Per Capita Water Consumption 101

REFRIGERATION:

Number of Service Calls 52 Number Repair Jobs 19 Ave. Total Number Employees 13

Number of Units Inspected and Serviced This Month 42

Units Not Operating: (give number and size) McCray-US 65 Universal Cooler 206295-2

Coldspot Unit 1976338

Sunbeam SA 623 Serial 1977933

Sunbeam SA 623 Serial 1976368

Explain why units not operating, how long idle, etc.

McCray- Missing parts idle 12 months

Coldspot-compressor out of order idle 8 months 3 weeks

Sunbeam Serial 1977933- idle 7 months, 2 weeks

Sunbeam Serial 1976368-idle 5 months, 1 week

COMMENTS: (Discuss here any unusual or significant developments this month in construction, land development, maintenance, operation of utilities and refrigeration; problems, or difficulties encountered in getting materials, labor or equipment; etc. Use additional sheet if necessary.)



## WAR RELOCATION AUTHORITY

Budget Bureau No. 13-R035  
Approval Expires: 8/30/44

ENGINEERING

For Month Ending April 30 194 4

## Monthly Report

Center Rohwer, Arkansas

**CONSTRUCTION:** Buildings, Irrigation, Drainage, Roads.

[illegible]

AGRICULTURAL LAND DEVELOPMENT: Clearing, Levelling, etc.

Type of Project	Date Started	% Done	Est. Date of Completion	Ave. No. Evacuees Employed	ACREAGE DEVELOPED	
					This Month	Total To Date



MAINTENANCE:

	Number of Jobs Done	Ave. Total Number Employees	Est. Value of Materials Used
On Buildings	261	2	371.23
On Utilities	3	2	13.84

OPERATION OF UTILITIES:

Average Number of Employees: Water Supply 12 Sewage Disposal 13 Electrical \_\_\_\_\_

Est. Value Materials Used: Water Supply 75.00 Sewage Disposal 76.00 Electrical \_\_\_\_\_

Gallons Water Used This Month 21,000,000 Per Capita Water Consumption 100 gal.day

REFRIGERATION:

Number of Service Calls 36 Number Repair Jobs 39 Ave. Total Number Employees 13

Number of Units Inspected and Serviced This Month 40

Units Not Operating: (give number and size) McCray-US 65 Universal Cooler 206295-2  
Coldspot Unit 1976338

Sunbeam SA 623 Serial 1977933  
Sunbeam SA 623 Serial 1976368

Explain why units not operating, how long idle, etc.

**McCray** Missing parts Idle 13 months

**Coldspot**, compressor out of order, Idle 9 mo 3 wks

**Sunbeam 1977933** Idle 8 mo 2 wks

**Sunbeam 1976368-compressor** Idle 5 mo 1 wk

COMMENTS: (Discuss here any unusual or significant developments this month in construction, land development, maintenance, operation of utilities and refrigeration; problems, or difficulties encountered in getting materials, labor or equipment; etc. Use additional sheet if necessary.)







MAINTENANCE:

	Number of Jobs Done	Ave. Total Number Employees	Est. Value of Materials Used
On Buildings	744	12	610.54
On Utilities	2	6	.32

OPERATION OF UTILITIES:

Average Number of Employees: Water Supply 12 Sewage Disposal 13 Electrical       

Est. Value Materials Used: Water Supply 80.00 Sewage Disposal 75.00 Electrical       

Gallons Water Used This Month 22,000,000 Per Capita Water Consumption 105 Gals.

REFRIGERATION:

Number of Service Calls 22 Number Repair Jobs 40 Ave. Total Number Employees 13

Number of Units Inspected and Serviced This Month 40

Units Not Operating: (give number and size) McCray #65, Universal Cooler #206295-2  
4-Cold Spot Unit 1976338  
Sunbeam SA623-Serial 1977933  
Sunbeam SA 623-Serial 1976368

Explain why units not operating, how long idle, etc.

**McCray - Missing parts - Idle 14 month's**

**Cold Spot - Compressor - out of order - Idle 10 months, 3 weeks**

**Sunbeam - Idle - 9 months, 2 weeks**

**Sunbeam - Compressor - out of order - Idle 5 months, 1 week**

COMMENTS: (Discuss here any unusual or significant developments this month in construction, land development, maintenance, operation of utilities and refrigeration; problems, or difficulties encountered in getting materials, labor or equipment; etc. Use additional sheet if necessary.)







MAINTENANCE:

	Number of Jobs Done	Ave. Total Number Employees	Est. Value of Materials Used
On Buildings	887	18	816.86
On Utilities	9	10	23.74

OPERATION OF UTILITIES:

Average Number of Employees: Water Supply 12 Sewage Disposal 13 Electrical       

Est. Value Materials Used: Water Supply \$90.00 Sewage Disposal \$25. Electrical       

Gallons Water Used This Month 25,000,000 Per Capita Water Consumption 170

REFRIGERATION:

Number of Service Calls 39 Number Repair Jobs 43 Ave. Total Number Employees 13

Number of Units Inspected and Serviced This Month 40

Units Not Operating: (give number and size)       

Explain why units not operating, how long idle, etc.

COMMENTS: (Discuss here any unusual or significant developments this month in construction, land development, maintenance, operation of utilities and refrigeration; problems, or difficulties encountered in getting materials, labor or equipment; etc. Use additional sheet if necessary.)







MAINTENANCE:

	Number of Jobs Done	Ave. Total Number Employees	Est. Value of Materials Used
On Buildings	350	11	328.20
On Utilities	305	9	602.83

OPERATION OF UTILITIES:

Average Number of Employees: Water Supply 12 Sewage Disposal 13 Electrical 5

Est. Value Materials Used: Water Supply \$100.00 Sewage Disposal \$50.00 Electrical \$109.64

Gallons Water Used This Month 33,684,700 Per Capita Water Consumption 135 gals  
day

REFRIGERATION:

Number of Service Calls 41 Number Repair Jobs 29 Ave. Total Number Employees 12

Number of Units Inspected and Serviced This Month 40

Units Not Operating: (give number and size) \_\_\_\_\_

Explain why units not operating, how long idle, etc.

COMMENTS: (Discuss here any unusual or significant developments this month in construction, land development, maintenance, operation of utilities and refrigeration; problems, or difficulties encountered in getting materials, labor or equipment; etc. Use additional sheet if necessary.)







MAINTENANCE:

	Number of Jobs Done	Ave. Total Number Employees	Est. Value of Materials Used
On Buildings	754	17	1192.62
On Utilities	13	6	25.95

OPERATION OF UTILITIES:

Average Number of Employees: Water Supply 12 Sewage Disposal 13 Electrical 4  
 Est. Value Materials Used: Water Supply 475 Sewage Disposal 420 Electrical 48.42  
 Gallons Water Used This Month 31,741,000 Per Capita Water Consumption 128 gal. day

REFRIGERATION:

Number of Service Calls 40 Number Repair Jobs 38 Ave. Total Number Employees 11  
 Number of Units Inspected and Serviced This Month 40  
 Units Not Operating: (give number and size) \_\_\_\_\_  
 Explain why units not operating, how long idle, etc.

COMMENTS: (Discuss here any unusual or significant developments this month in construction, land development, maintenance, operation of utilities and refrigeration; problems, or difficulties encountered in getting materials, labor or equipment; etc. Use additional sheet if necessary.)







MAINTENANCE:

	Number of Jobs Done	Ave. Total Number Employees	Est. Value of Materials Used
On Buildings	608	11	604.55
On Utilities	10	7	127.97

OPERATION OF UTILITIES:

Average Number of Employees: Water Supply 12 Sewage Disposal 13 Electrical 4

Est. Value Materials Used: Water Supply 100.00 Sewage Disposal 50.00 Electrical 113.58

Gallons Water Used This Month 27,126,000 Per Capita Water Consumption 113 Gals.  
Day

REFRIGERATION:

Number of Service Calls 48 Number Repair Jobs 30 Ave. Total Number Employees 7

Number of Units Inspected and Serviced This Month 40

Units Not Operating: (give number and size) \_\_\_\_\_

Explain why units not operating, how long idle, etc.

COMMENTS: (Discuss here any unusual or significant developments this month in construction, land development, maintenance, operation of utilities and refrigeration; problems, or difficulties encountered in getting materials, labor or equipment; etc. Use additional sheet if necessary.)







MAINTENANCE:

	Number of Jobs Done	Ave. Total Number Employees	Est. Value of Materials Used
On Buildings	216	5	465.80
On Utilities	533	8	573.01

OPERATION OF UTILITIES:

Average Number of Employees: Water Supply 12 Sewage Disposal 13 Electrical 4

Est. Value Materials Used: Water Supply 5.14 Sewage Disposal 75.00 Electrical 2.50

Gallons Water Used This Month 23,653,000 Per Capita Water Consumption 100 gals.

REFRIGERATION:

Number of Service Calls 45 Number Repair Jobs 35 Ave. Total Number Employees 7

Number of Units Inspected and Serviced This Month 43

Units Not Operating: (give number and size) \_\_\_\_\_

Explain why units not operating, how long idle, etc.

COMMENTS: (Discuss here any unusual or significant developments this month in construction, land development, maintenance, operation of utilities and refrigeration; problems, or difficulties encountered in getting materials, labor or equipment; etc. Use additional sheet if necessary.)







MAINTENANCE:

	Number of Jobs Done	Ave. Total Number Employees	Est. Value of Materials Used
On Buildings	240	5	606.57
On Utilities	522	8	559.14

OPERATION OF UTILITIES:

Average Number of Employees: Water Supply 12 Sewage Disposal 13 Electrical 4

Est. Value Materials Used: Water Supply 4.30 Sewage Disposal 25.00 Electrical 1.25

Gallons Water Used This Month 23,000,000 Per Capita Water Consumption 100

REFRIGERATION:

Number of Service Calls 24 Number Repair Jobs 26 Ave. Total Number Employees 8

Number of Units Inspected and Serviced This Month 43

Units Not Operating: (give number and size) \_\_\_\_\_

Explain why units not operating, how long idle, etc.

COMMENTS: (Discuss here any unusual or significant developments this month in construction, land development, maintenance, operation of utilities and refrigeration; problems, or difficulties encountered in getting materials, labor or equipment; etc. Use additional sheet if necessary.)







MAINTENANCE:

	Number of Jobs Done	Ave. Total Number Employees	Est. Value of Materials Used
On Buildings	158	10	577.36
On Utilities	549	7	671.22

OPERATION OF UTILITIES:

Average Number of Employees: Water Supply 12 Sewage Disposal 13 Electrical 4  
 Est. Value Materials Used: Water Supply 125.00 Sewage Disposal 22.00 Electrical 7.79  
 Gallons Water Used This Month 24,773,000 Per Capita Water Consumption 115 gal/day

REFRIGERATION:

Number of Service Calls 21 Number Repair Jobs 20 Ave. Total Number Employees 9  
 Number of Units Inspected and Serviced This Month 42  
 Units Not Operating: (give number and size) \_\_\_\_\_  
 Explain why units not operating, how long idle, etc.

COMMENTS: (Discuss here any unusual or significant developments this month in construction, land development, maintenance, operation of utilities and refrigeration; problems, or difficulties encountered in getting materials, labor or equipment; etc. Use additional sheet if necessary.)







MAINTENANCE:

	Number of Jobs Done	Ave. Total Number Employees	Est. Value of Materials Used
On Buildings	302	14	93.53
On Utilities	536	10	533.73

OPERATION OF UTILITIES:

Average Number of Employees: Water Supply 12 Sewage Disposal 13 Electrical 4

Est. Value Materials Used: Water Supply 120.00 Sewage Disposal 25.00 Electrical 12.19

Gallons Water Used This Month 23,560,000 Per Capita Water Consumption 108 gal. day

REFRIGERATION:

Number of Service Calls 20 Number Repair Jobs 18 Ave. Total Number Employees 9

Number of Units Inspected and Serviced This Month 42

Units Not Operating: (give number and size) \_\_\_\_\_

Explain why units not operating, how long idle, etc.

COMMENTS: (Discuss here any unusual or significant developments this month in construction, land development, maintenance, operation of utilities and refrigeration; problems, or difficulties encountered in getting materials, labor or equipment; etc. Use additional sheet if necessary.)







MAINTENANCE:

	Number of Jobs Done	Ave. Total Number Employees	Est. Value of Materials Used
On Buildings	156	14	70.70
On Utilities	346	10	397.79

OPERATION OF UTILITIES:

Average Number of Employees: Water Supply 12 Sewage Disposal 13 Electrical 4

Est. Value Materials Used: Water Supply 100.00 Sewage Disposal 25.00 Electrical 3.43

Gallons Water Used This Month 21,000,000 Per Capita Water Consumption 107 gals

REFRIGERATION:

Number of Service Calls 10 Number Repair Jobs 13 Ave. Total Number Employees 9

Number of Units Inspected and Serviced This Month 42

Units Not Operating: (give number and size) \_\_\_\_\_

Explain why units not operating, how long idle, etc.

COMMENTS: (Discuss here any unusual or significant developments this month in construction, land development, maintenance, operation of utilities and refrigeration; problems, or difficulties encountered in getting materials, labor or equipment; etc. Use additional sheet if necessary.)







MAINTENANCE:

	Number of Jobs Done	Ave. Total Number Employees	Est. Value of Materials Used
On Buildings	308	15	380.55
On Utilities	312	5	318.42

OPERATION OF UTILITIES:

Average Number of Employees: Water Supply 12 Sewage Disposal 13 Electrical 4

Est. Value Materials Used: Water Supply \$100.00 Sewage Disposal \$25.00 Electrical \$11.12

Gallons Water Used This Month 24,749,900 Per Capita Water Consumption 110

REFRIGERATION:

Number of Service Calls 6 Number Repair Jobs 35 Ave. Total Number Employees 10

Number of Units Inspected and Serviced This Month 42

Units Not Operating: (give number and size) 0

Explain why units not operating, how long idle, etc.

COMMENTS: (Discuss here any unusual or significant developments this month in construction, land development, maintenance, operation of utilities and refrigeration; problems, or difficulties encountered in getting materials, labor or equipment; etc. Use additional sheet if necessary.)







MAINTENANCE:

	Number of Jobs Done	Ave. Total Number Employees	Est. Value of Materials Used
On Buildings	320	15	376.13
On Utilities	299	5	240.45

OPERATION OF UTILITIES:

Average Number of Employees: Water Supply 17 Sewage Disposal 13 Electrical 5

Est. Value Materials Used: Water Supply \$105. Sewage Disposal \$30. Electrical \$5.01

Gallons Water Used This Month 23,000,000 Per Capita Water Consumption 120 gals.  
day

REFRIGERATION:

Number of Service Calls 11 Number Repair Jobs 31 Ave. Total Number Employees 9

Number of Units Inspected and Serviced This Month 42

Units Not Operating: (give number and size) \_\_\_\_\_

Explain why units not operating, how long idle, etc.

COMMENTS: (Discuss here any unusual or significant developments this month in construction, land development, maintenance, operation of utilities and refrigeration; problems, or difficulties encountered in getting materials, labor or equipment; etc. Use additional sheet if necessary.)







MAINTENANCE:

	Number of Jobs Done	Ave. Total Number Employees	Est. Value of Materials Used
On Buildings	240	10	164.92
On Utilities	428	11	506.10

OPERATION OF UTILITIES:

Average Number of Employees: Water Supply 12 Sewage Disposal 13 Electrical 6  
 Est. Value Materials Used: Water Supply 110. Sewage Disposal 100. Electrical 141  
 Gallons Water Used This Month 24,000,000 Per Capita Water Consumption 130 gals

REFRIGERATION:

Number of Service Calls 8 Number Repair Jobs 40 Ave. Total Number Employees 9  
 Number of Units Inspected and Serviced This Month 42  
 Units Not Operating: (give number and size) 0  
 Explain why units not operating, how long idle, etc.

COMMENTS: (Discuss here any unusual or significant developments this month in construction, land development, maintenance, operation of utilities and refrigeration; problems, or difficulties encountered in getting materials, labor or equipment; etc. Use additional sheet if necessary.)







MAINTENANCE:

	Number of Jobs Done	Ave. Total Number Employees	Est. Value of Materials Used
On Buildings	156	11	\$59.20
On Utilities	379	12	

OPERATION OF UTILITIES:

Average Number of Employees: Water Supply 12 Sewage Disposal 11 Electrical 6  
 Est. Value Materials Used: Water Supply \$120 Sewage Disposal \$85 Electrical \$273.03  
 Gallons Water Used This Month 18,000,000 Per Capita Water Consumption 120 gals.


REFRIGERATION:

Number of Service Calls 11 Number Repair Jobs 34 Ave. Total Number Employees 7  
 Number of Units Inspected and Serviced This Month 42  
 Units Not Operating: (give number and size) 2

Explain why units not operating, how long idle, etc.

M. P. Hess closed

COMMENTS: (Discuss here any unusual or significant developments this month in construction, land development, maintenance, operation of utilities and refrigeration; problems, or difficulties encountered in getting materials, labor or equipment; etc. Use additional sheet if necessary.)









MAINTENANCE:

	Number of Jobs Done	Ave. Total Number Employees	Est. Value of Materials Used
On Buildings	78	8	\$31.87
On Utilities	2		\$85.00

OPERATION OF UTILITIES:

Average Number of Employees: Water Supply 12 Sewage Disposal 10 Electrical 5  
 Est. Value Materials Used: Water Supply \$105 Sewage Disposal \$20 Electrical \$373.16  
 Gallons Water Used This Month 15,000,000 Per Capita Water Consumption 125

REFRIGERATION:

Number of Service Calls 9 Number Repair Jobs 35 Ave. Total Number Employees 6  
 Number of Units Inspected and Serviced This Month 42  
 Units Not Operating: (give number and size) 2  
 Explain why units not operating, how long idle, etc.

**Messhalls closed.**

COMMENTS: (Discuss here any unusual or significant developments this month in construction, land development, maintenance, operation of utilities and refrigeration; problems, or difficulties encountered in getting materials, labor or equipment; etc. Use additional sheet if necessary.)







MAINTENANCE:

	Number of Jobs Done	Ave. Total Number Employees	Est. Value of Materials Used
On Buildings	47	7	3.40
On Utilities	202	8	200.00

OPERATION OF UTILITIES:

Average Number of Employees: Water Supply 12 Sewage Disposal 0 Electrical 3

Est. Value Materials Used: Water Supply 200 Sewage Disposal 40 Electrical 212

Gallons Water Used This Month 400,000 Per Capita Water Consumption 125

REFRIGERATION:

Number of Service Calls 9 Number Repair Jobs 31 Ave. Total Number Employees 7

Number of Units Inspected and Serviced This Month 42

Units Not Operating: (give number and size) 2

Explain why units not operating, how long idle, etc.

~~Boss hall closed~~

COMMENTS: (Discuss here any unusual or significant developments this month in construction, land development, maintenance, operation of utilities and refrigeration; problems, or difficulties encountered in getting materials, labor or equipment; etc. Use additional sheet if necessary.)







MAINTENANCE:

	Number of Jobs Done	Ave. Total Number Employees	Est. Value of Materials Used
On Buildings	165	15	25.64
On Utilities	197	3	231.18

OPERATION OF UTILITIES:

Average Number of Employees: Water Supply 12 Sewage Disposal 8 Electrical 3

Est. Value Materials Used: Water Supply \$215.00 Sewage Disposal \$18.00 Electrical \$26.67

Gallons Water Used This Month 6,000,000 Per Capita Water Consumption 85 gals.

REFRIGERATION:

Number of Service Calls 8 Number Repair Jobs 21 Ave. Total Number Employees 5

Number of Units Inspected and Serviced This Month 42

Units Not Operating: (give number and size) 2

Explain why units not operating, how long idle, etc. Mess halls closed

COMMENTS: (Discuss here any unusual or significant developments this month in construction, land development, maintenance, operation of utilities and refrigeration; problems, or difficulties encountered in getting materials, labor or equipment; etc. Use additional sheet if necessary.)



For Month Ending Oct. 31 1945

Monthly Report

ENGINEERING

Center      ~~Solover~~

CONSTRUCTION: Buildings, Irrigation, Drainage, Roads.

[illegible]

AGRICULTURAL LAND DEVELOPMENT: Clearing, Levelling, etc.

Type of Project	Date Started	% Done	Est. Date of Completion	Ave. No. Evacuees Employed	ACREAGE DEVELOPED This Month	DEVELOPED Total To Date



MAINTENANCE:

	Number of Jobs Done	Ave. Total Number Employees	Est. Value of Materials Used
On Buildings			
On Utilities	57	0	433.00
	153	3	216.59

OPERATION OF UTILITIES:

Average Number of Employees: Water Supply 10 Sewage Disposal 0 Electrical 0  
 Est. Value Materials Used: Water Supply 4120 Sewage Disposal 0 Electrical 4216.59  
 Gallons Water Used This Month 7,200,000 Per Capita Water Consumption 120 gal.

REFRIGERATION:

Number of Service Calls 0 Number Repair Jobs 20 Ave. Total Number Employees 0  
 Number of Units Inspected and Serviced This Month 42  
 Units Not Operating: (give number and size) 10  
 Explain why units not operating, how long idle, etc.

Mess halls closed.

COMMENTS: (Discuss here any unusual or significant developments this month in construction, land development, maintenance, operation of utilities and refrigeration; problems, or difficulties encountered in getting materials, labor or equipment; etc. Use additional sheet if necessary.)